



NOTE:
Polarity of Red & Blue motor wires are reversed from RH to LH operators

NOTE:
For Knowing Act Applications all activation devices connect to the purple wires (N.O. dry contact only). The purple wires connect in parallel be sure to observe polarity (+ to +, - to -).
If Equipped, Push/Pull activation must be DISABLED at the Door Control.

INSTALLATION NOTES
1. Set door speeds and verify proper door operation prior to final connections of sensors system.
2. Technician MUST WALK TEST to verify function and detection patterns comply with ANSI/BHMA A156.10 requirements.

| Dipswitch Settings | OFF | ON |
|--------------------|-----------|-------------|
| 1. Safety Output | N.O. | N.C. |
| 2. Stall Output | N.O. | N.C. |
| 3. Auto / K.A. | Automatic | Knowing Act |
| 4. Future Use | | |

Tables for 904 dipswitch settings

| Fully Automatic | Knowing Act |
|-----------------|-------------|
| 1. OFF | 1. OFF |
| 2. ON | 2. ON |
| 3. OFF | 3. ON |
| 4. OFF | 4. OFF |

Title: Hunter FA Old Style Simultaneous Pair with Elite
 Drawing # 01HUNFAOLDELI02
 Drawing By: SDR Date: 05-29-08 Sheet: 1 of 1

Optex Technologies Inc.
 3882 Del Amo Blvd., Suite 604, Torrance, CA 90503
 Office: (800)877-6656, Fax: (310)214-8655