



Dipswitch Settings		OFF	ON
1. Safety Output	N.O.	N.C.	N.C.
2. Stall Output	N.O.	N.C.	N.C.
3. Auto / K.A.	Automatic	Knowing Act	Knowing Act
4. Future Use			

Fully Automatic	Knowing Act
1. OFF	1. OFF
2. OFF	2. OFF
3. OFF	3. ON
4. OFF	4. OFF

- INSTALLATION NOTES**
1. Set door speeds and verify proper door operation prior to final connection of sensors system.
 2. Technician MUST WALK TEST to verify function and detection patterns comply with ANSI/BHMA A156.10 requirements.

NOTE:
For Knowing Act applications all activating devices must connect to the purple wires of the OC-904 controls (N.O. dry contact only).

Title: KM 2000 Operator with Elite & Electric Lock		Drawing # 01KEA2000ELI03
Drawing By: JAS	Date: 06-05-08	Sheet: 1 of 1
Optex Technologies Inc. 3882 Del Amo Blvd., Torrance, CA 90503 Office: (800)877-6656, Fax: (310)214-8655		